**Two Way FRR** 

E3SQa30

# <u>**Q**</u>uiet <u>S</u>teel Frame

**<u>3</u>** Layers: 1 Layer of Plasterboard to one side of the frame & 2 Layers of Plasterboard to other side of the frame

Sub Intertenancy **a**coustic

System Number	Lining	Eire Dating	Load Bearing		Control	Lining Dequirement	
System Number	Suffix	Fire Rating	Ability	STC	Rw	Lining Requirement	
F260-20	-S39	/30/30	NLB	53	52	1 x 13mm Elephant Standard on One side 2 x 13mm Elephant Standard to Other side	
E3SQa30	-M30	/30/30	NLB	53	52	1 x 10mm Elephant MultiSmart on One side 2 x 10mm Elephant MultiSmart to Other side	

## Framing

**Quiet Steel Frame** – Channels to be 92mm x 30mm x 0.55 BMT and are fixed to floor and ceiling. Quiet Steel studs 92mm x 45mm x 0.55 BMT are friction fitted and placed at 600mm centres with a 15mm expansion gap at top of frame.

No fixings to the top channel allowed.

## Wall Heights

Recommended maximum height is 3.6m. Higher walls may be subject to specific engineering design or consult the framing manufacturer.

### **Partition Width**

In order to achieve the STC ratings in the table above the partition width (excluding the board) shall be a minimum of 92mm.

Stud Size	Lining Suffix	Plasterboard	<b>Total Partition</b>
92mm	M30	30mm	122mm
	S39	39mm	131mm

## Wall Sound Absorber

Install Sound Absorber between studs of the frame.

Use 90mm thick R2.2 glass wool blanket.

# **Plasterboard Lining**

One layer of Elephant Plasterboard lining on one side and Two layers on the other side as per specified system above.

Vertical fixing only permitted. Vertical joints of the outer layer should be offset by 600mm from those of the inner layer. Use full height sheets where possible. The inner layers are fixed hard to the floor. All sheet joints must be fixed over steel framing. Sheet end butt joints must be formed over nogs and offset the outer layer joints from the inner layer. Sheets shall be touch fitted.

# Fixing of Linings (Non Fire Rated)

Fix the linings as per the Elephant Installation Guide. If an FRR is required then follow the Fixing of Linings instruction in the following paragraph.

#### Fixing of Linings (to achieve Fire Rating) Fasteners (As per Specified System Above)

Non Load Bearing

	Side	Side Two				
System Number	1 <sup>st</sup> Layer	2 <sup>nd</sup> Layer	Single Layer			
	Self-Tapping Drywall Screws					
F260-20 M20	10mm	10mm	10mm			
E3SQa30-M30	25 x 6g	32 x 6g	25 x 6g			
5260.20.620	13mm	13mm	13mm			
E3SQa30-S39	25 x 6q	41 x 6q	25 x 6q			

#### **Fastener Centres**

Inner layer: Fix at 600mm centres up all studs.

Single or Outer Layer: Fix at 300mm centres up all studs.

Place fasteners 12mm from the sheet edge and 50mm from sheet ends.

Place fasteners at 200mm centres where sheet end butt joints occur. Avoid outer layer screws from hitting inner layer screws.

### **Acoustic Sealant**

A bead of acoustic sealant is required around the perimeter of the steel framing and the single layer is bedded into the bead. The perimeter junctions of the wall must be airtight.

# Jointing

# Inner Layer: Unstopped

Outer or Single Layer: All fastener heads stopped and all sheet joints reinforced with paper jointing tape and stopped. Wall to ceiling junctions are to be reinforced with paper tape and square stopped or finished with Cornice. All in accordance with Elephant Plasterboard Installation Guide.

